

Jordan Lake Water Supply Program

May 1, 2024



**Western Intake
Partnership**

- Welcome
- Introductions (around the entire room)
- Western Intake Partnership program overview
 - What's new?
- PER Spotlight: Raw Water Intake, Pump Station and Transmission
- What to expect next
- Q & A
- Networking
- Adjourn



Introductions






Western Intake Partnership program overview



- Represents diverse cross section of Triangle communities
- Collaborating on regional water supply solution since 2014
- Formed to ensure sufficient water supply for the Partners' current customers & support long-term growth & resiliency – access Partners' Jordan Lake allocations from state
- Even with development of other supplies, WIP facilities provide needed capacity to support resiliency and growth

- City of Durham - Contracting Entity
 - Project Manager – Sydney Miller
- HDR - Program Manager
 - Not eligible to be a design engineer on the Program
 - Supports Selection Committees, but not a voting member
- All Meeting and/or Information Requests shall be directed to HDR:
 - Jeff Adkins – jeff.adkins@hdrinc.com
 - Kip Kalisiak – kip.kalisiak@hdrinc.com

Western Intake Partnership Water Supply Project



- Access Partners' Jordan Lake allocations
- Jointly plan, design, construct and operate:
 - *Jordan Lake Intake, Tunneled Raw Water Pipeline (~3/4 mile) & Pump Station*
 - **Progressive Design-Build Opportunity**
 - *Regional Water Treatment Facility (initial capacity 20 mgd, site plan for future expansions to 77 mgd)*
 - **Progressive Design-Build Opportunity**
 - *Finished Water Transmission Pipelines Initial 16 miles to Durham/Chatham; Pittsboro pipeline in future phase*
 - *2 Elevated Water Storage Tanks*
 - **Traditional Design-Bid-Build**

Finished Water
Transmission Pipeline


Raw Water Intake
Raw Water Transmission
(Tunnel)

Raw Water PS



Regional Water
Treatment Facility

- Key Decisions that led Partners to PDB:
 - “Reserving” an A-Team Contractor/Engineer; recognize limited resources in the market
 - Collaborative approach
 - Quals-based selection
 - Risk mitigation
- Important Factors to Partners
 - Locally-based project leadership
 - Consistency with project leadership team
 - Need to show separate teams if pursuing multiple contracts
 - Contractor capacity to self-perform significant portion of work



What's new since WIP May 2023 Outreach Event?

- Clearer picture of Partner participation and capacity allocations
- Decisions on construction contract delineations and delivery methods
- Preliminary Engineering Reports nearing completion
 - Surveys and Geotech investigations
 - Raw Water Intake, Pump Station and Transmission PER – submitted for final review
 - Regional Water Treatment Facility PER – expected June
 - Finished Water Transmission – PER nearly complete
 - Final work to identify intermediate & northern elevated storage tank locations
- Fieldwork for Environmental Assessment (wetlands, streams, species surveys, cultural & historic resources)
 - EA prepared for submittal to USACE and DEQ

Current Preliminary Construction Cost Estimate

PDB Program Element	Preliminary Estimate (\$M)
Intake, Raw Water Pumping & Transmission	\$117M
Regional Water Treatment Facility	\$460M

DBB Program Element	Preliminary Estimate (\$M)
Finished Water Transmission to Durham	\$152M (36-in)
	\$190M (42-in)
Two Elevated Storage Tanks	\$21M

Total Program Preliminary Estimate (PDB + DBB Elements) = \$750M-\$788M

Construction Costs only, excluding Design, Permitting & Administration
Costs in 2024 dollars


- Lake eutrophic from the beginning
- Seasonal taste & odor issues (MIB, Geosmin)
- Nutrient Management
 - Jordan Lake Rules
 - NC Collaboratory study late 2019
- Emerging contaminants (PFAS, 1,4-dioxane, Bromide)
- Intake WQ analysis 2021-present
 - WQ data will be shared
- Proposed intake
 - Near Vista Point State Rec Area
 - Historic New Hope Creek

Proposed Raw Water Design Conditions

Parameter	Normal	Challenging
Turbidity, NTU	8.4	>20
Tot Manganese, mg/L	0.12	>1
Tot Iron, mg/L	0.23	>0.3
Bromide, µg/L	138.5	>200
MIB, ng/L	9.7	>150
Geosmin, ng/L	14.3	>100
1,4-Dioxane, µg/L	1.15	1.5
Tot Microcystins, µg/L	0.25	>1.2
PFOA, ng/L	6.6	7.4*
PFOS, ng/L	9.5	10.5*
PFBS, ng/L	5.8	6.3*

* 75th percentile of historic data

Finished Water Transmission Pipelines to Partners



- Traditional Delivery project
- Transmission pipelines along roadways from Treatment Facility
- 16-mile transmission pipeline from Treatment Facility to Durham and Chatham Co. water distribution systems
 - Chatham County interconnect location TBD
 - OWASA receives WIP water through existing Durham interconnects, emergencies only during initial phase
 - Future parallel pipeline
- Future 6-mile transmission pipeline to Pittsboro


WIP is using Envision to encourage Sustainability



Tools to plan, design, construct, operate and rate civil infrastructure

- Framework to help project teams identify sustainable approaches
- Self-assessment checklist
- Project verification & recognition program

Speaks to triple bottom line: social, economic & environmental goals



QUALITY OF LIFE



LEADERSHIP



RESOURCE ALLOCATION



NATURAL WORLD



CLIMATE & RESILIENCE



PER Spotlight

Raw Water Intake, Pump Station
and Transmission

Raw Water Intake, Pump Station and Transmission PER Overview

Hazen Hazen and Sawyer
4011 Westchase Blvd, Suite 500
Raleigh, NC 27607 • 919.833.7152



**Western Intake
Partnership**

Raw Water Intake, Pump Station, and Transmission – Alternatives Evaluation Technical Memorandum

Draft TM

Hazen No 31507-000
February 6, 2024

- One of 3 Hazen PER Tech Memos
 - Others are related to Finished Water Transmission program element
 - Draft final Memo submitted late April
- Final version will be available for review on request later this month

- WTF PER to be finalized ~September
- Expect similar overview and availability on request

Alternatives analysis for new Raw Water facilities


Goal: Convey water from west side of Jordan Lake to Partners' new Water Treatment Facility

Sections:

- Introduction & Background
- In-Situ and Modeling Investigations
- Location Alternatives for Raw Water Intake & Pump Station
- Raw Water Intake Alternatives
 - Screen Type
 - Configuration (Tower/Submerged)
- Intake Piping Trenchless Alternatives
- Recommended Raw Water Intake & Piping Configuration
- Raw Water Pump Station Configuration
- Raw Water Intake Alternatives
- Raw Water Transmission Configuration
- Construction Cost Estimate


Guiding Design Principles for Raw Water Infrastructure

- Thalweg Access – resilient to severe drought
 - Vicinity bathymetric survey completed
- Sustainable pumping operation above flood elevation, including access to station during flood event
- Intake capable of multi-level withdrawals as needed for seasonal WQ challenges
 - Changing intake elevation is infrequent
 - In-lake modeling built on 2018 *Jordan Lake Nutrient Management Report* models
- Minimize disturbance to Vista Point Rec Area




Intake Location

- Initially evaluated 1991
- WIP evaluated 3 in-lake intake locations – Bells Landing, 2 areas off Vista Point
- Preferred location – north of Vista Point




Raw Water Pump Station Location

- Consideration limited to locations not impacted by flood conditions
- Preferred location – SE corner of property owned by OWASA
- Fewer issues with access, easements




View from Vista Point Sailboat Launch toward Proposed Intake Location



Raw Water Intake Configuration Alternatives

Evaluated two intake configurations:

- In-lake Tower Style Intake w/ integral gates for intake level control
- Submerged Screen Style Intake with onshore gates



Preferred option:

**Concrete In-Lake Tower
Tee Barrel Screens
3 Withdrawal Elevations
ultimate 86 MGD capacity**



- Local Reservoir Intake Examples
- Agency input during 2023 important to intake style selection

NC Parks, NC Wildlife Resources Commission, NC Div. of Water Resources


- Construction impacts to Park in either option
 - Submerged intake structure requires on-land gate structure
 - Concerns operating/maintaining permanent WIP structures in Park
 - Tower intake presents navigational hazard challenges; requires lighting and buoys
 - Potential security concerns similar to Falls Lake
- Intake will be accessed by boat for O&M
 - Not practical to run power to Intake to operate gates, provide lighting
 - Public safety, security, lighting important design considerations
 - Vista Point Recreation Area must be closed during construction

Raw Water Intake Piping Alternatives

Both *open-cut* and *tunnel* raw water intake pipeline construction initially discussed

...but early determined tunnel would be needed to address intake depth + USACE, NC Parks concerns

- Geotechnical investigation to assess subsurface conditions, characterize rock along tunnel alignment
- Seismic Risk Index low




Soil Borings – 10 along two potential tunnel routes


PRELIMINARY GEOTECHNICAL REPORT OF SUBSURFACE INVESTIGATION

TABLE OF CONTENTS

SECTION 1: PROJECT INFORMATION	5
1.1 PROJECT DESCRIPTION	5
1.2 SITE DESCRIPTION	5
1.3 SITE GEOLOGIC DESCRIPTION	5
1.3.1 THE TRIASSIC BASIN	5
1.3.2 DIABASE	6
1.3.3 METAMORPHIC ROCKS	6
1.4 TOPOGRAPHICAL DATA	7
SECTION 2: PURPOSE AND SCOPE	8
SECTION 3: FIELD INVESTIGATION	9
3.1 SITE RECONNAISSANCE AND PROJECT SET-UP	9
3.2 SOIL TEST BORINGS	9
SECTION 4: LABORATORY TESTING	10
4.1 SOIL AND ROCK TESTING	10
TABLE 4.1: SUMMARY OF ROCK SAMPLE TESTING	10
4.1 HISTORIC TEST DATA	11
TABLE 4.2: SUMMARY OF DIABASE ROCK SAMPLE TESTED FOR OTHER PROJECTS	11
FIGURE 4.1A AND 4.1B: ROCK SAMPLES AFTER COMPRESSIVE STRENGTH TESTING	11
SECTION 5: SUBSURFACE CONDITIONS	12
5.1 SURFACE MATERIALS, SOIL, AND ROCK	12
5.2 GROUNDWATER MEASUREMENTS	12
5.3 VISUALIZATION OF SUBSURFACE DATA	13
SECTION 6: PRELIMINARY GEOTECHNICAL CONSIDERATIONS	14
6.1 POTENTIAL GEOLOGICAL HAZARDS	14
6.2 SITE EXCAVATION	15
6.3 GROUNDWATER	15
TABLE 6.1: SUMMARY OF GROUNDWATER READINGS	15
FIGURE 6.1: PUBLISHED INTRINSIC PERMEABILITY AND HYDRAULIC CONDUCTIVITY VALUES	17
6.4 SUBSURFACE CONDITIONS	17
SECTION 7: CLOSURE	19



Boring Location Plan/Profile




NOTES:
 1. Georeferenced aerial imagery obtained from WNC OneMap.
 2. All boring locations are based on subsurface data. Actual conditions may differ.
 3. This sheet is intended to be printed on 11x17 sized paper.

FALCON ENGINEERING
 PROJECT NO.: G21007.00
 PROJECT LOCATION: JORDAN LAKE, NORTH CAROLINA
 INVESTIGATED BY: RWL / D/J
 DATE: 2021-09-10

North

NAD 83 / NSRS / 2007



SHEET NAME: BORING LOCATION PLAN-PROFILE

PROJECT NAME: WIP INTAKE AND TRANSMISSION INFRASTRUCTURE

PROJECT NO.: G21007.00

PROJECT LOCATION: JORDAN LAKE, NORTH CAROLINA

INVESTIGATED BY: RWL / D/J


H. SCALE: 1"=200'

V. SCALE: 1"=20'

CHECKED BY: JRH

DRAWN BY: ASP

Boring Location Plan/Profile



NOTES:
 1. Georeferenced aerial imagery obtained from www.NCOneMap.gov.
 2. Stratigraphy inferred from subsurface data. Actual conditions may differ.
 3. This sheet is intended to be printed on 11x17 sized paper.

FALCON
 ENGINEERING & CONSTRUCTION, INC.
 1700 TRINITY ROAD, SUITE 110
 CARY, NC 27513
 www.falconeng.com

DATE: 2021-09-10



SHEET NAME: BORING LOCATION PLAN-PROFILE
PROJECT NAME: WIP INTAKE AND TRANSMISSION INFRASTRUCTURE
PROJECT NO.: G21007.00
PROJECT LOCATION: JORDAN LAKE, NORTH CAROLINA
INVESTIGATED BY: RWL / DIG
DRAWN BY: ASP
CHECKED BY: JRH
H. SCALE: 1"=200'
V. SCALE: 1"=20'



Raw Water Pipeline Trenchless Alternatives



PLAN
SCALE: 1" = 200'



PROFILE
HORIZONTAL SCALE: 1" = 200'
VERTICAL SCALE: 1" = 2'

Raw Water Intake and Piping Configuration

- Preliminarily, Partners may consider alternate Tunnel options, leverage PDB Team input on most cost-effective
- Recognize contractor & TBM equipment availability are factors

Table 7-1: Recommended Intake and Piping Configuration

Design Feature	Selection	
Intake Location	Vista Point – Area 1 ¹	
Pump Station Location	OWASA-owned Seaforth Property	
Intake Design		
Configuration	Tower	
Screen Technology	Tee-Style Barrel Screens	
Screen Barrel / Outlet Diameter	60 inches / 48 inches	
Slot Size	1/8-inch	
Screen Capacity	~23 mgd	
Screen Isolation	48-inch Butterfly Valve	
Withdrawal Elevations	3 – EL 207.00, EL 200.50, EL 182.50	
Screen Quantity per Withdrawal Elevation	2 (Initial Construction), 4 (Build-Out)	
Trenchless Technology		
TBM		
Tunnel / Piping Design²	Option 1	Option 2
Tunnel Diameter	8 feet	12 feet
Intake Piping Quantity / Diameter	1 / 66 inches	2 / 48 inches

Raw Water Pump Station Configuration

- Pump Station wet well is launch point for tunnel construction
- 22 MGD initial pumping capacity







Table 8-1: Capacity Requirements

Planning Horizon	Capacity, mgd
Initial	20 (Finished Water) / 22 (Raw Water)
2050	26 (Finished Water) / 29 (Raw Water)
2070	40 (Finished Water) / 44 (Raw Water)
Build-Out	86 (Raw Water)

- Ultimate build-out capacity based on max demand corresponding to remaining Jordan Lake allocations not accessed at Cary-Apex
- Initial pumping & above-ground piping based on 2050 demand
- Initial 4 vertical turbine pumps (2x7 mgd, 2x10 mgd)
- 56-ft circular wet well, Hydraulics Institute
- Electrical room

Figure 8-3: Circular Wet Well Configuration – Iteration 2





- Zoning requires 100-ft vegetated buffer
- Chemical storage & feed facilities for WTF will also provide for RW facilities
- Raw water pumped to WTF's raw water reservoirs


- WIP PERs will be available to interested engineers and contractors
 - Final *Raw Water Intake, Pump Station & Transmission PER* ready in May
 - *Water Treatment Facility PER* – draft submitted in June, final August-September; available when final
- Contact Jeff Adkins/HDR to request
- Other useful information and links for WIP projects available at
 - WIP website www.westernintakepartnership.com
 - Chatham County website www.chathamcountync.gov , 2024 rezoning page



What to expect next



PDB Delivery Schedule



By Late Summer


- Preliminary Engineering TMs complete
- PDB Teams can schedule presentations with WIP
- Expect Non-Recreational Outgrant applications submitted to USACE
- Interlocal Agreement ready for Partners approval

By end of 2024

- Finished Water Transmission survey, easement requirements
- Outgrant applications prompt Agency EA review & opportunity for public input

Early 2025

- 1st PDB RFQ




- Working on DB contract documents and RFQs
- City of Durham is WIP's Contracting Agent
- Planning solicitations for PDB Contracts in 2025
 - 1st RFQ – Water Treatment Facility (Contract 2) – March/April
 - 2nd RFQ – Intake & Raw Water Facilities (Contract 1) – June/July
- Not planning to issue 2nd RFQ until selection made on 1st RFQ
- 2-stage selection – SOQ, Interviews
 - Structured evaluation – criteria will be in RFQ

Traditional Delivery Project – 16-mile Finished Water Transmission Pipeline – Hazen to continue to final design, anticipate bidding 2027

- All construction projects – PDB and Traditional - will have goals for Underutilized Business Enterprise (UBE) participation
 - % Minority-owned and % Women-owned UBE firms
- Underutilized Business Enterprise Compliance Division in Finance Department; requirements at City's website
<https://www.durhamnc.gov/4091/Underutilized-Business-Compliance-Divisi>
email: ubcfinance@durhamnc.gov
- RFQ will explain UBE requirements with forms all proposers are required to complete
 - UBE Participation Documentation
 - Consultant Workforce Diversity Questionnaire
 - Letter(s) of Intent to Perform as a Sub-Consultant

westernintakepartnership.com



The screenshot shows the homepage of the Western Intake Partnership website. The browser address bar displays "https://westernintakepartnership.com". The navigation menu includes "Who We Are", "Jordan Lake Water Supply", "Stay Updated", "FAQ", "Get Involved", "Work With Us", and "Contact Us". The "Work With Us" and "Contact Us" links are circled in red. The main content area features a teal background with a white wave pattern and a central text block: "Durham, Pittsboro, Chatham County and Orange Water and Sewer Authority are partners in solving our long-term water supply needs." Below this is a "Learn More" button. A white box titled "Our Mission" contains the text: "To continue to provide reliable, high quality drinking water to the Triangle region." and a right-pointing arrow. Below the mission box is a "Our Work" section with a large water drop icon and the text: "The Western Intake Partnership is committed to working together across utility organizations and community boundaries to provide the best possible service to our customers in Pittsboro, Durham, Chatham County, and OWASA. We are focused on securing a long-term water supply for the communities we serve." Below this is a "Recent Updates" button. The bottom of the page shows three small icons: a water tap, a water drop, and a house.

August - September: WIP Partner Staff & HDR representatives available to meet with PDB Teams

Framework:

- 1.5 hr slots
- 8 time slots, first-come first-served
- PDB Teams – not engineers or contractors individually
- Separate meetings for each PDB opportunity, or meet jointly
- Sign-up with Jeff Adkins/HDR
- Structured framework
 - Introductions
 - Overview
 - PDB Team approach to project delivery
 - PDB Lessons learned
 - Market conditions affecting WIP
 - Questions (submit ahead)

August WIP Construction Industry Outreach Event – Updates & WTF Prelim. Engineering Report Overview



Meeting and/or Information Requests

Jeff Adkins – jeff.adkins@hdrinc.com

Kip Kalisiak – kip.kalisiak@hdrinc.com





Q & A




Networking

A decorative vertical bar on the left side of the slide, featuring a light blue and white wavy pattern.


Extra Slides for Q&A

Raw Water Pipeline Trenchless Alternatives

- 6 trenchless alternatives considered
- After initial screening & decision for In-Lake Intake Tower, 2 alternatives remained



Raw Water Pump Station Configuration



August WIP Construction Industry Outreach Event – Updates & WTF Prelim. Engineering Report Overview



KEY:

- 1 ADMIN/ OPERATIONS BUILDING (227'x51')
- 2 MAINTENANCE BUILDING (110'x98')
- 3 SUBSTATION / TRANSFORMERS (90'x75')
- 4 7.5MG RAW WATER STORAGE TANK (2 No. 190' DIA.)
- 5 RAW WATER OZONE INJECTION BUILDING AND CONTACTORS (66'x40')
- 6 RAPID MIX (37'x16')
- 7 FLOCCULATION (6 No. 62'x19')
- 8 SEDIMENTATION BASINS WITH PLATE SETTLERS (4 No. 70'x30')
- 9 OZONE GENERATORS AND SETTLED WATER CONTACTORS (152'x66')
- 10 FILTERS (152'x130')
- 11 GAC (123'x114')
- 12 HSPS (195.5'x75')
- 13 5MG CLEARWELL (2 No. 160' DIA.)
- 14 ELECTRICAL / GENERATORS BLDG (120'x110')
- 15 CHEMICAL BLDG (200'x100')
- 16 LOX STORAGE (60'x45')
- 17 GRAVITY THICKENER (2 No. 62' DIA.)
- 18 THICKENED SOLIDS PS (70'x30')
- 19 DEWATERING BLDG (92'x92')
- 20 THICKENED SOLIDS STORAGE (2 No. 42' DIA.)
- 21 BW EQ BASIN (80'x60')
- 22 BW PLATE SETTLERS AND RECYCLE PS (90'x40')
- 23 RECLAMATION BASINS (2 No. 175'x175')
- 24 SEPTIC DRAINAGE FIELD (150'x150')
- 25 RAW WATER PUMP STATION (95'x70')
- 26 PAC SILO (14' DIA.)
- 27 OPTIONAL WEIGH STATION (100'x12')
- 28 FUEL STORAGE FOR STANDBY GENERATORS (60'x45')
- 29 CAKE STORAGE (160'x120')
- 30 DUPLEX SEPTIC PS (12'x6') AND VALVE BOX (3'x3')
- 31 ELECTRICAL BUILDING (60'x40')
- 32 POSSIBLE IX (250'x105')
- 33 SURGE TANKS (35'x20')
- 34 FUTURE RO OR GAC/IX


LEGEND:

- PROPOSED FACILITY - 30 MGD (PHASE 1- 2031)
- POSSIBLE FUTURE FACILITIES - 40 MGD (PHASE 2)
- POSSIBLE FUTURE FACILITIES TO BUILDOUT (PHASE 3)
- ASPHALT ROAD
- CONCRETE PAVEMENT
- GRAVEL ROAD
- WETLAND
- OPEN WATER
- APPROXIMATE LOCATION OF EXISTING CEMETERY (TO BE REVISED FOLLOWING DETERMINATION OF CEMETERY BOUNDARY)
- STORMWATER CONTROL MEASURE (SCM)
- EPHEMERAL STREAM
- INTERMITTENT STREAM
- 60' SETBACK FROM INTERMITTENT STREAM
- WIP RWTF
- 50' SETBACK FROM PROPERTY LINE
- 100' SETBACK FROM PROPERTY LINE
- 100' SETBACK FROM ROADS
- PERIMETER FENCE

Water Treatment Facility Operations Building – Rendering of Preliminary Concept



Water Treatment Facility Hydraulic Profile



Raw Water Tanks

Raw Water Ozone

Rapid Mix Basins


Flocculation Basins

Sedimentation Basins

Settled Water Ozone

Filters

Filtered Water Weir Box



Filtered Water Weir Box

Adv Treatment Feed / Cart Filters / Adv Treatment Vessels

Finished Water Clearwells

Finished Water PS